

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/07/2011  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155152</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02 , 01</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>01/05/2011</b>	
NAME OF PROVIDER OR SUPPLIER  <b>MONTICELLO ASSISTED LIVING AND HEALTHCARE</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>1120 NORTH MAIN STREET</b> <b>MONTICELLO, IN 47960</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p><b>INITIAL COMMENTS</b></p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 11/17/10 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 01/05/11</p> <p>Facility Number: 000072 Provider Number: 155152 AIM Number: 100287440</p> <p>Surveyor: Bridget Brown, Life Safety Code Specialist</p> <p>At this PSR survey, Monticello Assisted Living and Healthcare was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This fully sprinklered facility consisted of a one story building of Type V (000) construction with a partial basement and a two story building determined to be Type V (111) construction. Later renovations were completed prior to March,1 2003. The facility was surveyed as two buildings due to different construction Types. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors. The facility has a capacity for 147 residents and had a census of 115 at the time of this survey.</p> <p>Quality Review by Robert Booher, REHS, Life</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/07/2011  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155152</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02 , 01</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>01/05/2011</b>
NAME OF PROVIDER OR SUPPLIER  <b>MONTICELLO ASSISTED LIVING AND HEALTHCARE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>1120 NORTH MAIN STREET</b> <b>MONTICELLO, IN 47960</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	Continued From page 1 Safety Code Specialist-Medical Surveyor on 01/06/11.	{K 000}			